

CODES ADMINISTRATION

PLAN REVIEW CONDITIONS

September 28, 2018

TRUE POINT CONSTRUCTION LLC
8426 CLINT DR, SUITE 350
BELTON, MO 64012

Permit No: PRCOM20183218
Project Title: THE LEVEL SALON
Project Address: 415 SW JEFFERSON ST, LEES SUMMIT, MO 64063
Parcel Number: 61410151200000000
Location: LEES SUMMIT TOWN OF LOT 20 BLK 9
Type of Work: CHANGE OF TENANT
Occupancy Group: BUSINESS
Description: CHANGE OF TENANT FOR HAIR SALON WITH NO NAIL SERVICE

**drawings are in plan review file

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Development Services Department (816) 969-1200

Fire Department (816) 969-1300

Licensed Contractors

Reviewed By: Joe Frogge

Approved

1. Lee's Summit Code of Ordinance, Section 7-130.4 - Business License. (excerpt)

No person, other than a licensed contractor or employees of a licensed contractor, shall engage in electrical, plumbing or mechanical business, construction, installation or maintenance unless duly licensed in accordance with this section.

Action required: MEP subcontractors are required to be listed on permit. Provide company name of licensed Plumbing contractor.

Building Plan Review

Reviewed By: Joe Frogge

Rejected

1. A License Tax application completed by the contractor must be submitted to the City of Lee's Summit, Codes Administration Department, and any applicable License Tax paid prior to issuing a building permit.

Action required: Comment is for informational purposes.

Fire Plan Review

Reviewed By: Joe Dir

Approved with Conditions

1. 2012 IFC 505.1- Address numbers. New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. In Multi-tenant commercial building where tenants have multiple entrances located on different sides of the building, each door shall be addressed. Address numbers shall be Arabic numerals or alphabet letters. Numbers shall be a minimum of 4 inches (102 mm) high with a minimum stroke width of 0.5 inch (12.7 mm).

ACTION REQUIRED:(veriifed at inspection)
Address shall be readable form roadway

2. 2012 IFC 906.2- General requirements. Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10.

ACTION REQUIRED: (veriifed at inspection)

If not existing provide a minimum of one 2A-10BC fire extingusiher. Fire extinguisher is to be mounted on a wall close to an exit.

- Approved to issue per the listed conditions.
- Do not issue per the listed conditions.
- Approved to construct foundation only per the listed conditions.
- Requires Final Development Plan approval prior to issuing this building permit.

The applicant agrees to incorporate the aforementioned requirements into the project to conform to applicable City Codes and Ordinances.

Signature of Applicant	Date
------------------------	------

Print Applicant Name	CompanyName
----------------------	-------------

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.