

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20180307, Building Permit - Residential

Address: 1809 SW BLACKSTONE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Jason McRoy	Failed	Friday, September 28, 2018

Corrective Action Required

- | | | |
|---|------|--|
| 1 | Misc | <ul style="list-style-type: none">• tighten outlet in garage nw• Smoke alarm in basement needs to be combination smoke/ carbon• Install box extension /spark arrestor at master fire place outlet• Smoke alarm in master bedroom needs to be a combination smoke/ carbon because of the fireplace• Driveway inspection needed• Sidewalk inspection needed |
|---|------|--|

Plot Plan Inspection	Jason McRoy	Passed	Friday, September 28, 2018
-----------------------------	-------------	--------	----------------------------

Comments: