

**PUBLIC WORKS ENGINEERING DIVISION**

**Inspection Summary**

Permit #: PRSITE20174026, Development - Site  
Lee's Summit Surgical Center  
Address: 2801 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

**Inspection Item:**

<b>Inspection:</b>	<b>Inspector:</b>	<b>Outcome:</b>	<b>Date:</b>
DEI-Storm - Pipe	John Jackson	Partial	Tuesday, October 02, 2018

**Informational**

- 1 Contractor installed approximately 70' feet of 18" HDPE storm pipe on line 10 & a 4'X4' junction box at station 10+12.74. Curb inlet at station 10+00 was modified according to field plans and approx. 12' feet 24" HDPE storm pipe was connect to newly installed junction box. John Jackson 10/02/2018 7:26 AM

**Comments:**