

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20182476, Building Permit - Residential

Address: 2321 NE LAKE BREEZE LN, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pool Steel/Bonding - Residential	Khanh Nguyen	Passed	Tuesday, October 02, 2018

Comments:

POOL COMPONENTS BONDED: POOL WATER, PERIMETER, HANDRAIL, LADDER, BONDING JUMPER TO EQUIPMENTS LOCATION