

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20181780, Building Permit - Residential
Address: 1709 SW MERRYMAN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Piping Inspection - Residential	Jason McRoy	Passed	Tuesday, October 02, 2018
Gas Service Inspection - Residential	Jason McRoy	Passed	Tuesday, October 02, 2018
Electrical Service Inspection - Residential	Jason McRoy	Passed	Tuesday, October 02, 2018
All Rough Inspection - Residential	Jason McRoy	Failed	Tuesday, October 02, 2018

Corrective Action Required

- | | | |
|---|------|--|
| 1 | Misc | <ul style="list-style-type: none">• protect nm wiring within 6' at attic access in garage• Fire block at heat flue, radon, plumbing chase stuff top with min wool• Nail off all double joists per code top bottom on both sides• Over notched rim joist for plumbing on main fl guest bath. Provide engineers report.• Fire stop nm electrical penetrations inside return air spaces in kitchen• Fire stop at dryer vent• Add anchor at northeast corner garage sill plate• |
|---|------|--|

**Water Service
Inspection - Residential**

Jason McRoy

Passed

Tuesday, October 02, 2018

Comments: