

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20180896, Building Permit - Residential
Address: 1617 SW MERRYMAN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Piping Inspection - Residential	Jason McRoy	Passed	Tuesday, October 02, 2018
Gas Service Inspection - Residential	Jason McRoy	Passed	Tuesday, October 02, 2018
Electrical Service Inspection - Residential	Jason McRoy	Passed	Tuesday, October 02, 2018
All Rough Inspection - Residential	Jason McRoy	Failed	Tuesday, October 02, 2018

Corrective Action Required

- | | | |
|---|------|---|
| 1 | Misc | <ul style="list-style-type: none">• nail all double joists both sides• Fire stop all horizontal nm electrical penetrations in combustion and return air spaces in kitchen• Fire stop at thermostat wire penetrations in return air space• Fire stop unused penetrations at south bump out in basement• Protect nm electrical and water lines along Joists in basement by heat ac duct• Heat flue within 6" of combustible surface at radon in basement•• |
|---|------|---|

Comments: