

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRRES20181063, Building Permit - Residential

Address: 1609 SW MERRYMAN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Jason McRoy	Failed	Wednesday, October 03, 2018

### Corrective Action Required

- |   |      |   |
|---|------|---|
| 1 | Misc | 1. outlet on dishwasher side of island not working.<br>2. raise water meter and sprinkler box up to grade |
|---|------|---|

### Comments: