

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRSUBD20162865, Development - Subdivision

Address:

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Storm - Pipe	John Jackson	Partial	Thursday, October 04, 2018

Informational

- 1 Poured inverts on storm sewer inlets that were installed completely. Backfilled storm sewer pipes and inlets. John Jackson 09/28/2018 3:09 PM

Informational

- 2 Contractor installed approved modification Storm Sewer revised storm line 13 new storm line 17 pg C. 304 . Approximately 100' feet of 18" HDPE pipe was installed on storm line 17 & New 5'X4' Curb Inlet.

Comments: