

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRSITE20180219, Development - Site
MERIDIAN AT VIEW HIGH APARTMENTS
Address: 201 NW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Fire Line - Hydrostatic Test	Steve Robbins	Partial	Thursday, October 04, 2018

Informational

- 1 The hydrostatic pressure twst for the 4" service line has been passed. They are planning on possibly doing the fire line today.Steve Robbins 10/01/2018 9:51 AM

Informational

- 2 The hydrostatic pressure test for fire line has passed 200psi for 2hrs. This is a partial completion of the water lines that have been installed.Steve Robbins 10/04/2018 7:54 AM

Comments: