

Temporary Certificate of Occupancy

Permit #: PRRES20173335
Address: 1709 NE PARKWOOD DR, LEES SUMMIT, MO 64064
Inspected On: Thursday, October 04, 2018
Inspected By: Khanh Nguyen
Expiration Date: 11/5/2018 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

| Inspection: | Inspector: | Outcome: | Date: |
|---|--------------|------------------|-------------------------------|
| Occupancy Inspection - Codes Residential | Khanh Nguyen | Temporary C of O | Thursday, October 04, 2018 |

Corrective Action Required:

1 Misc -Deck ledger lag screws must go through the spacer.