

---

**PUBLIC WORKS ENGINEERING DIVISION**

## **Inspection Summary**

---

Permit #: PRSITE20174026, Development - Site

Lee's Summit Surgical Center

Address: 2801 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection Item:

<b>Inspection:</b>	<b>Inspector:</b>	<b>Outcome:</b>	<b>Date:</b>
DEI-Storm - Pipe	John Jackson	Partial	Friday, October 05, 2018

Informational

- 1 Contractor installed 30' feet of HDPE 24" on Storm Line 11 & new 4'X4" Field Inlet @ Sta 16+35.09. Contractor continued to modify existing tops of Curb Inlets. John Jackson  
10/05/2018 8:00 AM

**Comments:**

---