

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20180838, Building Permit - Residential

Address: 1841 SW BLACKSTONE CT, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Jason McRoy	Failed	Friday, October 05, 2018

Corrective Action Required

- | | | |
|---|------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 2 | Misc | <ul style="list-style-type: none">• fire stop gas line and unused hole at fireplace• Finish fire stopping above fireplace, fill cracks and openings• Firestop unused penetration in top plate at west wall in great room left of stairs• Strap top plate in stairwell where wall transitions from 2x6 to 2x4• Add joist hangers at deck joists under door• Provide engineers report on hinged 2x6 walls in stairway. |
|---|------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|

Comments: