

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20181069, Building Permit - Residential

Address: 1705 SW MERRYMAN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Jason McRoy	Failed	Friday, October 05, 2018

Corrective Action Required

- | | | |
|---|------|---|
| 1 | Misc | <ul style="list-style-type: none">• oven is not installed• Missing cover plates in downstairs bath• Smoke alarm in furnace room needs to be a combination smoke/ carbon• Sod• Splash blocks• |
|---|------|---|

Comments: