

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20181780, Building Permit - Residential

Address: 1709 SW MERRYMAN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Jason McRoy	Failed	Friday, October 05, 2018

Corrective Action Required

2	Misc	* FIRE STOP AT DRYER VENT TO ATTIC * PROVIDE ENGINEERS REPORT ON NOTED RIM JOIST IN GUEST BATH ON MAIN FLOOR. * OK TO INSULATE *
---	------	--

Comments: