

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRRES20180715, Building Permit - Residential

Address: 4825 NE JAMESTOWN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Steve Robbins	Passed	Friday, October 05, 2018

Informational

1 The driveway has been installed and appears to meet city standards. Steve Robbins
10/05/2018 3:53 PM

DEI-Sidewalk Inspection	Steve Robbins	Passed	Friday, October 05, 2018
-------------------------	---------------	--------	--------------------------------

Informational

1 There appears to be 4" of rock and the rock was compacted. There is one area that is not 2% or less, I marked it with paint and let the contractor know that is was not right and told him he can still pour if he takes care of it. Steve Robbins 10/02/2018 8:23 AM

Informational

2 The sidewalk has been installed and appears to meet all city standards. Steve Robbins
10/05/2018 3:55 PM

Comments: