

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFC20173611, Public Works Infrastructure Permit - Commercial

Village at View High On-Site Infrastructure

Address: 3390 NW VILLAGE PARK DR, LEES SUMMIT, MO 640813391 NW VILLAGE PARK DR, LEES SUMMIT, MO 64081245 NW KESSLER DR, LEES SUMMIT, MO 64081201 NW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Sanitary Sewer - Air Test	Steve Robbins	Partial	Wednesday, October 10, 2018

Informational

1 We are doing air testing MH A-6 to A-5, A-5 to A-4, and A-4 to A-3 have all passed the air test.Steve Robbins 10/04/2018 8:24 AM

Informational

2 Sanitary Sewer Testing needs to be completed. Joe Starlin stayed late and finished the testing. Everything from A-6 to existing MH A-15 has been air tested and has passed.Steve Robbins 10/10/2018 3:11 PM

Comments: