

Temporary Certificate of Occupancy

Permit #: PRRES20173335
Address: 1709 NE PARKWOOD DR, LEES SUMMIT, MO 64064
Inspected On: Thursday, October 11, 2018
Inspected By: Khanh Nguyen
Expiration Date: 11/12/2018 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Temporary C of O	Thursday, October 11, 2018

Corrective Action Required:

1	Misc	-Deck ledger lag screws must go through the spacer. **I don't see any lag screw behind the joist hangers
---	------	---