

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20182146, Building Permit - Residential

Address: 1700 SW MERRYMAN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Residential	Jason McRoy	Passed	Monday, October 15, 2018

Corrective Action Required

1 Misc

Gas Piping Inspection - Residential	Jason McRoy	Passed	Monday, October 15, 2018
--	-------------	--------	--------------------------

Corrective Action Required

1 Misc

All Rough Inspection - Residential	Jason McRoy	Failed	Monday, October 15, 2018
---	-------------	--------	--------------------------

Corrective Action Required

2 Misc

* ADD HEADER AND HANGERS AT SOUTHEAST CORNER OF
BASEMENT WHERE JOIST IS CUT TO ACCOMMODATE
PLUMBING*

Comments: