

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20181678, Building Permit - Residential

Address: 4430 SW AMETHYST DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Jason McRoy	Failed	Monday, October 15, 2018

Corrective Action Required

- | | | |
|---|------|--|
| 1 | Misc | <ul style="list-style-type: none">• smoke alarm in basement needs to be a combination smoke / carbon• Install security screws at rear entry• Secure raceway at meter• SOD |
|---|------|--|

Comments: