

CODES ADMINISTRATION

PLAN REVIEW CONDITIONS

October 15, 2018

B & A ARCHITECTURE
100 W 31ST ST STE 100
KANSAS CITY, MO 64108

Permit No: PRCOM20182860
Project Title: TIKKA TWIST
Project Address: 697 NW BLUE PKWY, LEES SUMMIT, MO 64086
Parcel Number: 51700040900000000
Location / Legal: SUMMIT FAIR 3RD PLAT LOTS 15-27 & TRACTS F-I---LOT 17
Description:
Type of Work: CHANGE OF TENANT
Occupancy Group: ASSEMBLY FOR FOOD AND DRINK INC BARS, RESTAURANTS, BANQUET HALLS
Description: TENANT FINISH FOR A NEW RESTAURANT

Revisions Required

One or more departments have not approved the permit and the following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please address the comments as requested and provide three (3) copies of any revised sheets and/or additional information. Please contact the appropriate department regarding clarification of comments.

Development Services Department (816) 969-1200

Fire Department (816) 969-1300

Fire Plan Review

Reviewed By: Joe Dir

Rejected

1. 2012 IFC 1004.3- Posting of occupant load. Every room or space that is an assembly occupancy shall have the occupant load of the room or space posted in a conspicuous place, near the main exit or exit access doorway from the room or space. Posted signs shall be of an approved legible permanent design and shall be maintained by the owner or authorized agent.
ACTION REQUIRED:(verified at inspection)

2. 2012 IFC 907.1.1- Construction documents. Construction documents for fire alarm systems shall be submitted for review and approval prior to system installation. Construction documents shall include, but not be limited to, all of the following: 1. A floor plan which indicates the use of all rooms. 2. Locations of alarm-initiating and notification appliances. 3. Alarm control and trouble signaling equipment. 4. Annunciation. 5. Power connection. 6. Battery calculations. 7. Conductor type and sizes. 8. Voltage drop calculations. 9. Manufacturers, model numbers and listing information for equipment, devices and materials. 10. Details of ceiling height and construction. 11. The interface of fire safety control functions.
ACTION REQUIRED:(information purposes)
Have the fire alarm system contractor provide shop drawings of any modifications to be done to the existing fire alarm system.

3. 2012 IFC 505.1- Address numbers. New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. In Multi-tenant commercial building where tenants have

CODES ADMINISTRATION

multiple entrances located on different sides of the building , each door shall be addressed. Address numbers shall be Arabic numerals or alphabet letters. Numbers shall be a minimum of 4 inches (102 mm) high with a minimum stroke width of 0.5 inch (12.7 mm).

ACTION REQUIRED:(verified at inspection)

Address shall be readable from the roadway

5. 2012 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

ACTION REQUIRED:(information purposes)

Have the fire sprinkler system contractor provide shop drawings of the modifications to be done to the fire sprinkler system.

6. 2012 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

ACTION REQUIRED:(information purposes)

Acceptance testing of the fire alarm system modifications and Type 1 kitchen hoods will be required prior to the final occupancy inspection. Contact the fire department to schedule testing. (816)969-1300

7. 2012 IFC 904.11.5- Portable fire extinguishers for commercial cooking equipment. Portable fire extinguishers shall be provided within a 30-foot (9144 mm) travel distance of commercial-type cooking equipment. Cooking equipment involving vegetable or animal oils and fats shall be protected by a Class K rated portable extinguisher.

ACTION REQUIRED:(verified at inspection)

Provide a K class fire extinguisher. The K class fire extinguisher is to be mounted under or close to the manual pull station.

8. 2012 IFC 906.2- General requirements. Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10.

ACTION REQUIRED:(verified at inspection)

Provide a minimum of two 2A-10BC fire extinguishers. The fire extinguishers are to be mounted on a wall close to an exit.

13. Solid fuel cooking

ACTION REQUIRED: Reference the following and provide information on how the requirements will be addressed for the solid fuel cooking Tandoor oven.

NFPA 96 Chapter 14 solid fuel cooking

14.3-hoods for solid fuel cooking

14.4 Exhaust for solid fuel cooking

14.6 Air movement for solid fuel cooking

14.7 Fire -extinguishing Equipment for solid fuel cooking.

14.7.9 Hose protection

14.9 Minimum Safety Requirements (all sections): Fuel storage, handling, and ash removal for solid fuel cooking

Building Plan Review

Reviewed By: Joe Frogge

Rejected

1. A License Tax application completed by the contractor must be submitted to the City of Lee's Summit, Codes Administration Department, and any applicable License Tax paid prior to issuing a building permit.

Action required: Comment is for informational purposes.

CODES ADMINISTRATION

2. For the Health Department inspection contact Deb Sees with the Jackson County Public Works Department, Environmental Health Division at (816) 847-7070. Health Department approval is required prior to receiving any type of Occupancy from the City of Lee's Summit.

Action required: Comment is for informational purposes.

8. Inadequate information to complete review.

Provide the following:

-
- Specify hood fan locations.
10/15/18 - Exhausts are not allowed to be within 10' of intakes. (ref: 2012 IMC 501.3.1)
-
- Provide detailed and complete hood designs.
10/15/18 - Only 1 copy found in submittal. Provide 2 more copies.

11. 2011 NEC 210.63 Heating, Air-Conditioning, and Refrigeration Equipment Outlet. A 125-volt, single-phase, 15- or 20-ampere-rated receptacle outlet shall be installed at an accessible location for the servicing of heating, air-conditioning, and refrigeration equipment. The receptacle shall be located on the same level and within 25 feet of the heating, air-conditioning, and refrigeration equipment. The receptacle outlet shall not be connected to the load side of the equipment disconnecting means.

Action required: Provide convenience power with 25' of all new rooftop equipment.

10/15/18 - Provide for makeup air unit also.

12. 2012 IMC 917.1 Cooking appliances. Cooking appliances that are designed for permanent installation, including ranges, ovens, stoves, broilers, grills, fryers, griddles and barbecues, shall be listed, labeled and installed in accordance with the manufacturer's installation instructions. Commercial electric cooking appliances shall be listed and labeled in accordance with UL 197. Household electric ranges shall be listed and labeled in accordance with UL 858. Microwave cooking appliances shall be listed and labeled in accordance with UL 923. Oil burning stoves shall be listed and labeled in accordance with UL 896. Solid-fuel-fired ovens shall be listed and labeled in accordance with UL 2162.

Action required: Provide verification that charcoal-fired oven will be compliant with UL 2162.

10/15/18 - Tandoor oven cut sheets provided do not show that they are compliant.

Licensed Contractors

Reviewed By: Joe Frogge

Rejected

1. Lee's Summit Code of Ordinance, Section 7-130.10 - Business License. It shall be unlawful for any person to engage in the construction contracting business without first obtaining a business license as required under the applicable provisions of Chapter 28 of the Lee's Summit Code of Ordinances.

Action required: Either a Class A or Class B license is required. Provide the name of the licensed general contractor.

10/15/18 - Acknowledged in letter.

2. Lee's Summit Code of Ordinance, Section 7-130.4 - Business License. (excerpt)

No person, other than a licensed contractor or employees of a licensed contractor, shall engage in electrical, plumbing or mechanical business, construction, installation or maintenance unless duly licensed in accordance with this section.

CODES ADMINISTRATION

Action required: MEP subcontractors are required to be listed on permit. Provide company names of licensed MEP contractors.

10/15/18 - Acknowledged in letter.

The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.