Development Services Department

220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20180570, Building Permit - Residential Address: 1621 SW MERRYMAN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Occupancy Inspection - Mark Harding Not Ready Wednesday, October 17, 2018

Codes Residential

Corrective Action Required

1 Misc locked no code doors locked

- missing outlet cover left of fire place
- Label smokes
- •Hvac heat flue within 6" of combustible surface
- Hot water heater flue within 6 " of combustible surface
- •Final grade
- Sod
- •Smoke alarm in utility room should be a combo
- •Cover for attic access in laundry rm

Comments: