

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRRES20181760, Building Permit - Residential

Address: 2416 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Electrical Service Inspection - Residential</b>	Mark Harding	Passed	Wednesday, October 17, 2018
<b>All Rough Inspection - Residential</b>	Mark Harding	Failed	Wednesday, October 17, 2018

### Corrective Action Required

1	Misc	<ul style="list-style-type: none"><li>-Missing double joist right of furnace.</li><li>-Block cantilever at bedroom and bsmt bath, per plans.</li><li>-Firestop fierpalce from attic</li><li>-Security blocking rear bsmt door.</li><li>-Firestop bsmt east wall 10' horizontal, fur down from joist space at bathroom and over bedroom window, -overcloset.</li><li>-Solid block over lbea, where shown on plans.</li><li>-Connect bathfan east bsmt bath</li><li>-Firestop Hole in bottom plate right of fire place</li><li>-Missing Nuts and washer west side of garage bottom wall plates.</li><li>-Firstop dead space back of shower 1st floor.</li><li>-Strap rear header 1st floor see portal framing detail.</li><li>-Nail all siding per code and portal wall framing.</li></ul>
---	------	--

<b>Gas Service Inspection - Residential</b>	Mark Harding	Passed	Wednesday, October 17, 2018
---	--------------	--------	-----------------------------

Comments: