
PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRSUBD20162865, Development - Subdivision

Address:

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Sanitary Sewer Construction Inspection	John Jackson	Partial	Wednesday, October 17, 2018

Informational

1 Contractor installed approximately 100' feet of 8" SDR-26 Sanitary Sewer main on Line C.
from sta 0+00 to 1+00 John Jackson 10/17/2018 3:27 PM

Comments:
