

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20181827, Building Permit - Residential

Address: 2420 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mark Harding	Failed	Friday, October 19, 2018

Corrective Action Required

1	Misc	Install erosion control where required before next inspection. -Fir stop fire place from attic. -J hanger I joist at stairs unfinished side. -SW bedroom missing fur down at ceiling over door. -Missing ridge legs in the garage see plans. -Revise plans showing Cantilevered wall on the north side of mud room, provide engineers report , missing LVL, roof change etc. - Install Ridge legs throughout over mstr, main span install all bracing per plans. -Brace lvl in attic 1/3 points per plans.
---	------	---

Electrical Service Inspection - Residential	Mark Harding	Passed	Friday, October 19, 2018
--	--------------	--------	--------------------------

Gas Service Inspection - Residential	Mark Harding	Passed	Friday, October 19, 2018
---	--------------	--------	--------------------------

Comments: