

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20180570, Building Permit - Residential

Address: 1621 SW MERRYMAN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Jason McRoy	Failed	Friday, October 19, 2018

Corrective Action Required

1	Misc	locked no code doors locked
		<ul style="list-style-type: none">•missing outlet cover left of fire place•Hvac heat flue within 6" of combustible surface•Hot water heater flue within 6 " of combustible surface

Comments: