

Inspection Summary

Permit #:PRCOM20181021, Building Permit - Commercial
Address: 2100 SE BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Mike Copeland	Partial	Monday, October 22, 2018
Partial Correction			
1	THE FOLLOWING AREAS ARE APPROVED	<ul style="list-style-type: none">-EXTERIOR SIDE OF STEEL AT PARAPET AREA SPRAY APPLIED FIRE PROOFING JAPPROVED-1ST LAYER SHAFT WALL APPROVED-1ST LAYER GYP APPROVED NORTH SIDE OF SOUTH WALL.-2nd layer 2 hour shaft wall approved	

Comments: