



DEVELOPMENT SERVICES

Inspection Summary

Permit #:PRRES20181851, Building Permit - Residential
Address: 1531 SW BLACKSTONE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|-------------|----------|---------------------------|
| All Rough Inspection - Residential | Jason McRoy | Partial | Tuesday, October 23, 2018 |

Corrective Action Required

2 Misc

ANCHOR 1 STEEL SUPPORT POST IN BASEMENT
*PROVIDE ENGINEERS REPORT ON CUT LVL IN MASTER
BEDROOM.

* OK TO INSULATE *

Comments: