

Inspection Summary

Permit #:PRCOM20171104, Building Permit - Commercial
Address: 1701 NW BLUE PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial		Failed	Tuesday, October 23, 2018
Corrective Action Required			
1	A305.7.2 Forward Approach	CLEAR FLOOR SPACE. Where the clear floor space is positioned for a forward approach, the alcove shall be 36 inches (915 mm) minimum in width where the depth exceeds 24 inches (610 mm).	

Comments: