

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20171104, Building Permit - Commercial
Address: 1701 NW BLUE PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

| | | | |
|-------------------------------------|------------|----------|---------------------------|
| Inspection: | Inspector: | Outcome: | Date: |
| Above Ceiling Inspection | | Failed | Tuesday, October 23, 2018 |

Corrective Action Required

| | | |
|---|------------------------|---|
| 1 | B2304.6 Wall sheathing | GENERAL CONSTRUCTION REQUIREMENTS. Except as provided for in Section 1405 for weatherboarding or where stucco construction that complies with Section 2510 is installed, enclosed buildings shall be sheathed with one of the materials of the nominal thickness specified in Table 2304.6 or any other approved material of equivalent strength or durability. |
|---|------------------------|---|

Comments: