

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20181846, Building Permit - Residential

Address: 1301 NE GOSHEN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

| | | | |
|--|--------------|----------|-----------------------------|
| Inspection: | Inspector: | Outcome: | Date: |
| Electrical Service Inspection - Residential | Khanh Nguyen | Failed | Wednesday, October 24, 2018 |

Corrective Action Required

1 Misc

-REDO THE REBAR GROUNDING CONNECTION. THE GROUNDING
ELECTRODE CONDUCTOR MUST BE WEDGED IN BETWEEN THE
GROOVES OF THE GROUNDING CLAMP

Comments: