

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20182982, Building Permit - Commercial
Address: 2717 NE SCRUGGS RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Electrical Inspection - Commercial	Khanh Nguyen	Failed	Wednesday, October 24, 2018

Corrective Action Required

1	Misc	METER ALREADY INSTALLED. ADDRESS IS NOT POSTED FOR THE SERVICE PEDESTAL. THERE IS NO KEY FOR ACCESS TO SERVICE EQUIPMENT
---	------	--

Comments: