

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20183183, Building Permit - Commercial
Address: 1601 NW BLUE PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

| | | | |
|---|------------|----------|-----------------------------|
| Inspection: | Inspector: | Outcome: | Date: |
| Underground Electrical Inspection - Commercial | John Borns | Partial | Wednesday, October 24, 2018 |

Comments: POINTS MARKED ON SITE ELECTRICAL DRAWING. OK TO COVER TRENCHED CONDUIT FROM (1) TO (2)

NOTE: FEED TO L.P. AT (3) IS EXISTING. NO CONDUIT NECESSARY BETWEEN (2) AND (3).