

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRRES20181829, Building Permit - Residential  
Address: 1325 NE BRANDYWINE RD, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Piers/Caissons Inspection - Residential</b>	Khanh Nguyen	Passed	Friday, October 26, 2018

**Comments:**