

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20181439, Building Permit - Commercial
Address: 3580 SW HOLLYWOOD DR, Unit:8, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Commercial	Jason McRoy	Failed	Friday, October 26, 2018

Corrective Action Required

1	Misc	* PLUMBING IS NOT BEDDED CORRECTLY. BED SOUTH END OF BUILDING
---	------	---

Comments: