

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20182297, Building Permit - Commercial
Address: 910 NW BLUE PKWY, Unit:Y, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Piping Inspection - Commercial	John Borns	Failed	Monday, October 29, 2018

Corrective Action Required

1	Misc	IFGC 408 GAS PIPING DRIP/DIRT LEG: MUST BE AT ELEVATION TO HAVE CAP REMOVED FOR CLEANING AND REPLACED. BOTTOM OF NIPPLE TO BE NO CLOSER TO ROOF THAN DEPTH OF CAP + 1/4".
---	------	---

Corrective Action Required

2	Misc	INSTALL PROPERLY SIZED CLAMPS AT ALL ROOFTOP PIPING SUPPORT BLOCKS
---	------	--

Comments: