

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20181021, Building Permit - Commercial
Address: 2100 SE BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Monday, October 29, 2018

Partial Correction

1	THE FOLLOWING AREAS ARE APPROVED	-EXTERIOR SIDE OF STEEL AT PARAPET AREA SPRAY APPLIED FIRE PROOFING JAPPROVED -1ST LAYER SHAFT WALL APPROVED -1ST LAYER GYP APPROVED NORTH SIDE OF SOUTH WALL. -2nd layer 2 hour shaft wall approved; LINER BOARD AT WALL, BULKHEAD, AND LID AT BREAKTHRU OPENING 1-1458;
---	----------------------------------	--

IN-WALL APPROVED AT: NEW AND MODIFIED WALLS AT 1-B01431 + CORRIDOR WALLS JUST OUTSIDE CASED OPENING UNDER CONSTRUCTION;

Comments: