

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20181760, Building Permit - Residential
Address: 2416 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mark Harding	Failed	Tuesday, October 30, 2018

Corrective Action Required

1	Misc	-Firestop bsmt east wall 10' horizontal, fur down from joist space at bathroom and over bedroom window, -overcloset. FIRESTOP OVER FUR DOWN FROM JOSIT SPACE AT CEILING HEIGHT. (bathroom bedrrom ceiling ,closet, over window)
---	------	--

Comments: