

**CITY OF LEE'S SUMMIT**  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816) 969-1200    FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRRES20181846, Building Permit - Residential  
Address: 1301 NE GOSHEN DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Electrical Service Inspection - Residential</b>	Khanh Nguyen	Failed	Wednesday, October 31, 2018

Corrective Action Required

1        Misc

-REDO THE REBAR GROUNDING CONNECTION. THE GROUNDING ELECTRODE CONDUCTOR MUST BE WEDGED IN BETWEEN THE GROOVES OF THE GROUNDING CLAMP  
\*\*LOCATE AND EXPOSE THE UFER CONNECTION. MUST BE ACCESSIBLE AT FINAL INSPECTION

**Comments:**