CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20181663, Building Permit - Residential Address: 1805 SW BLACKSTONE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Jason McRoy	Failed	Wednesday, October 31, 2018
Corrective Action Requir	ed		
1 Misc	•	add anchor at	west side of garage sill plate within
	12" of splice		
	•	•	south west garage sill plate within 12"
	of spli		
	•	Strap garage p	portal
	•		n box in return air space at pantry entry
	•	Flexible duct r	esting on top of can light fixtures in
	walk in closet master		
	•	Flexible duct r	esting on can light fixture in bed 2
	walk in closet		
	•	Gas line is not	bonded

Comments: