CITY OF LEE'S SUMMIT

Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20180476, Building Permit - Residential Address: 1345 NE BRANDYWINE RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Occupancy Inspection - Khanh Nguyen Failed Wednesday, October 31, 2018

Codes Residential

Corrective Action Required

. Misc -FINAL GRADE, SOD, SPLASHBLOCKS

-COMPLETE DECK

-SEWER TRACE BOX AND WIRE SHALL BE ACCESSIBLE AT GRADE

LEVEL

-LOWER WATER METER SO THAT THE METER TOP-LID DISTANCE

IS 14"-18"

-DO NOT BURY DECK CEDAR POSTS

-SEAL EXTERIOR: ABOVE AC DISCONNECT, AT GAS PIPING

PENETRATION

-INSTALL ADDRESS NEAR LIGHT SOURCE

-INSTALL LIGHT AT FRONT ENTRY

-ALL EXTERIOR DOORS-SCREW IN THE EMBEDDED METAL BRACE

TO STUDS

-INSTALL BOX EXTENSION FOR THE FIREPLACE TV OUTLET

-INSTALL ANTI-HAMMERING ARRESTORS FOR DISH WASHER AND

CLOTHES WASHER WATER SUPPLY

-GARAGE DOOR NOT SELF-CLOSING

-INSTALL HANDRAIL FOR THE GARAGE STAIR

-SECURE THE WATER SERVICE LINE

-INSTALL ANTI-BACKFLOW DEVICE FOR THE HOSE BIBB

-REMOVE THE UNDER-STAIR INSULATION PAPER FACING

-REMOVE ALL FOUNDATION WALL TIES

-THE STOOP SUSPENDED SLAB WAS NOT INSPECTED BY CITY.

HAVE ENGINEER INSPECT&OK

-LOCATE THE UFER GROUNDING CONNECTION

-SUPPORT AND SECURE THE EXPANSION TANK. INSTALL THE

COPPER WATER PIPE FOR RIGID SUPPORT OF THE TANK
-INSTALL THE P/T DISCHARGE PIPE TO WITHIN 6" OF FLOOR
-BOND THE GAS PIPING

Comments: