

**CITY OF LEE'S SUMMIT**  
**Development Services Department**  
**220 SE Green Street**  
**Lee's Summit, MO 64063**  
**(816) 969-1200      FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20171104, Building Permit - Commercial  
Address: 1701 NW BLUE PKWY, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Piers/Caissons Inspection - Commercial</b>	sysadmin	Failed	Wednesday, October 31, 2018

Corrective Action Required

1	B1802.2.4 Pile and pier foundations	FOUNDATION AND SOILS INVESTIGATIONS. Pile and pier foundations shall be designed and installed on the basis of a foundation investigation and report as specified in Sections 1802.4 through 1802.6 and Section 1808.2.2.
---	-------------------------------------	---

**Comments:**