## CITY OF LEE'S SUMMIT

Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

## **Inspection Summary**

Permit #:PRCOM20173222, Building Permit - Commercial Address: 4101 NE LAKEWOOD WAY, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Occupancy Inspection - Khanh Nguyen Failed Wednesday, October 31, 2018

**Codes Commercial** 

## Corrective Action Required

1 Misc

- -SUBMIT SPECIAL INSPECTION REPORT, INCLUDING THE
- RETAINING WALL
- -APPROVAL REQUIRED FROM: FIRE, PLANNING, WATER, FIELD SERVICE
- -UNDERGROUND ELECTRICAL, INCLUDING THE LIGHT POLE PIERS, WERE NOT INSPECTED
- -INSTALL ADDRESS LEGIBLE FROM STREET
- -SEAL ALL EXTERIOR WALL PENETRATIONS
- -INSTALL SIGNAGE FOR ALL RESTROOMS
- -ALL RESTROOMS SHALL HAVE NON-ABSORBANT FLOOR
- SURFACE. INSTALL 6" BASEBOARD
- -THE RECEPTACLE IN THE EMPLOYEE DRESSING SHALL BE GFCI
- -ADJUST THE EMPLOYEE RESTROOM DOOR CLOSER TO 5 LBS OR
- LESS
- -THE RESTROOM ACCESSIBLE FROM THE REAR BAY AREA HAS NO VERTICAL GRAB BAR
- -SECURE THE DRINKING FOUNTAIN RECEPTACLE
- -PAINT ROOFTOP GAS PIPING FOR PROTECTION
- -INSTALL A RECEPTACLE WITHIN 25 FT OF THE ROOFTOP MECHANICAL UNITS
- -INSTALL MAX. 25 AMP BREAKER FOR THE SERVER RM
- CONDENSER UNIT AND 40 AMP BREAKERS FOR THE HVAC RTU
- -SECURE EMT NEAR EAST EXIT DOOR BY TRANSFORMER
- -INSTALL A BONDING JUMPER SIZED PER NEC 250.66 ACROSS THE WATER BACKFLOW VALVE

| ****OK TO STOCK BUILDING | DO NOT OCCUPY*** |
|--------------------------|------------------|
|                          |                  |

**Comments:**