

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRSUBD20162865, Development - Subdivision
Address:

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DEI-Sanitary Sewer Construction Inspection	John Jackson	Partial	Friday, October 26, 2018

Informational

1	PW-Main inspection	Holthouse has started with MH c-10, they installed 8" sdr 26 pipe to Mh c-11. They are going toward c-12. I have checked the materials and everything appears to be correct. Steve Robbins 08/02/2018 9:01 AM
---	--------------------	---

Informational

2		Contractor completed the installation of sanitary sewer line. Installing approximately 140' feet of 8" SDR-26 PVC on line C Sta 1+90 to 3+30.
---	--	---

Comments: