

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRSUBD20162865, Development - Subdivision
Address:

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DEI-Sanitary Sewer - Vacuum	John Jackson	Partial	Friday, October 26, 2018

Informational
1

Vacuum test passed on Manholes on Line F,G & C on Maholes 10-14. The remaining portion of Line C will tested after it clears the 30 days after installation as per Spec. .

Comments: