

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRSUBD20162865, Development - Subdivision
Address:

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DEI-Sanitary Sewer Construction Inspection	John Jackson	Partial	Friday, October 26, 2018

Informational
1

Tracer wire passed on line F,G & C from Manholes 10-14. The test on the remaining tracer wire will be performed when the rest of Line C has passed the 30 day interval after installation as per Spec. .

Comments: