

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816) 969-1200    FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRSUBD20162865, Development - Subdivision  
Address:

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

|                                         |              |          |                          |
|-----------------------------------------|--------------|----------|--------------------------|
| Inspection:                             | Inspector:   | Outcome: | Date:                    |
| <b>DEI-Sanitary Sewer -<br/>Mandrel</b> | John Jackson | Partial  | Friday, October 26, 2018 |

Informational  
1

Mandrel passed on line F,G & C from Manhole 10-14. Line C will be completed after the required 30 days, after installation as per Spec. .

**Comments:**