

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRSUBD20162865, Development - Subdivision

Address:

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Storm - Pipe	John Jackson	Partial	Friday, October 05, 2018

Informational

1 John Jackson 10/05/2018 2:31 PM Contractor poured invert for newly installed Storm Inlet boxes. Installed storm approximately line 14 30' feet of 15" HDPE and storm line 15 30' feet of 15" HDPE. Curb Inlet 14-1 & 15-1 were installed.

DEI-Storm - Pipe	Partial	Friday, October 05, 2018
------------------	---------	--------------------------------

Comments: