

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20182297, Building Permit - Commercial
Address: 910 NW BLUE PKWY, Unit:Y, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	John Borns	Partial	Thursday, November 01, 2018

Partial Correction
3 Misc

**OK TO COVER WHEN READY ACT FRAMING + ABOVE-CEILING
SYSTEMS EXCEPT CRAFT AREA AND AT RECIRCULATION PUMP
AT 107 NE**

CHECK MC ELECTRICAL CABLE FOR SUPPORT AT 6' MAXIMUM
INTERVALS.

NO LINE VOLTAGE OR LOW VOLTAGE ELECTRICAL CABLE TO BE
SUPPORTED ON CEILING SUPPORT WIRES. SUPPORT FROM
IDENTIFIED SLACK WIRES.

SECURE RECIRCULATION PUMP TO STRUCTURE.

Comments: