CITY OF LEE'S SUMMIT

Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20171501, Building Permit - Residential Address: 1804 SW BLACKSTONE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Occupancy Inspection - Jason McRoy Failed Friday, November 02, 2018

Codes Residential

Corrective Action Required

Misc
water penetration on east side of house needs to be

sealed

Splash blocks

Security flood light on back of house is not mounted

properly

Smell gas at meter

Oven is not installed

Self closing hinges on garage entry door not

operating properly

• Stairs in garage require a hand railing

Window screens

Can light in rec room in basement is hanging out of

ceiling

Can light at bottom of stairs is not complete

• Smoke alarm in rec room is missing

Micro breaker needs lockout

Irrigation permit required

As graded plot plan required

Comments: