

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816) 969-1200    FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRRES20181663, Building Permit - Residential  
Address: 1805 SW BLACKSTONE PL, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Jason McRoy	Failed	Monday, November 05, 2018

Corrective Action Required

2	Misc	Box out switch box in return air space at pantry entry
---	------	--

\*OK TO INSULATE\*

**Comments:**